

CERTIFICATE OF COMPLIANCE

Certificate Number 20141213-E243588
Report Reference E243588-20140630
Issue Date 2014-DECEMBER-13

Issued to: HARDY PROCESS SOLUTIONS
SUITE 150
9440 CARROLL PARK DR
SAN DIEGO CA 92121

**This is to certify that
representative samples of** PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS
See next page for models


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations;
CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous
Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141213-E243588
Report Reference E243588-20140630
Issue Date 2014-DECEMBER-13


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G, Class III Hazardous Locations.

Weight Processor Instrument Models HI 6300, HI 6310, HI 6500 and HI 6510 may be followed by multiple sets of alpha numeric characters to indicate software and hardware options codes.

Accessory Display: Model HI 6120 and HI 6110.

Load Cell Summing Boxes: Model HI6010JB and HI6010IT, may be followed by alphanumeric characters to indicate enclosure and calibration hardware options.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

